



THE ADMINISTRATION OF UNION TERRITORY OF LADAKH

OFFICE OF THE DIRECTOR FIRE AND EMERGENCY SERVICES UT LADAKH

(e-mail-igp-ladakh@police.ladakh.gov.in)

(Office Phone No.01982-260888)

No: - PHQ/Dir/F&ES/UTL/2020- 4684

Dated:- 01/12/2020

Subject: Fire NOC in favour of Delhi Public School, Choglamsar, Leh

The report has been submitted by Superintendent of Police Fire and Emergency Services, Ladakh vide its office letter no. PHQ/SP/F&ES/UTL/2020-226 dated 13/11/2020 regarding the inspection of the instant school building which has been done by Divisional Fire Officer, Ladakh after making the spot visit. The detailed report of proposed Hotel building is as under:

Location/ Accessibility:

The School building is constructed and situated at Choglamsar, Leh. It is located at Longitude :77.597825, Latitude 34.128470. The Site is approximately 3.4 Kms away from Fire and Emergency Services Station, Leh and it takes 9 minutes to reach the site which is approachable for fire appliances.

Detail of building:

The school building is two storied with a semi basement having 62 rooms. In the ground floor there are 29 rooms with one window panel in each room. The window size in each room measures 11x6 feet and two sides of window have provision to open and the height of window from ground level is 5 feet. There are 3 exits in the ground floor. There are two stair cases and one Ramp wherein the size of stair case is 1.18 meter in width. There are 1500 students and staff in the school.

The following fire safety equipment's were found installed in school building:

01. The main gate size is 12 feet which is sufficient for the fire Tender to enter the premises of the school in case of emergency.
02. 13 number of fire extinguisher ABC type 5 kg capacity is installed in the building at strategic locations prominent enough to be located in case of emergency.
03. 05 number of sand bucket found placed in the building.

The following provisions detailed below as per NBC norms should be implemented:

At least 50 thousand liters of water underground tank should be immediately constructed in the school premises along with two yard hydrants duly fitted with high rated pump connected with the said underground water tank which can be readily used in case of any fire emergency.

Fire NOC is hereby issued in favour of Delhi Public School, Leh however the administration of the instant school is directed to construct the underground water reservoir and place yard hydrants as advised above well before the school is reopened after following the necessary COVID 19 protocols.

[Handwritten Signature]
for Director, F&ES, Ladakh
PHQ, Agaling, Leh
11/12/20

Copy to:

1. Principal, Delhi Public School, Choglamsar for information and n/a.
2. Superintendent of Police, F&ES, Ladakh for information and with the direction to direct DFO, F&ES Leh for necessary creation of Underground water reservoir within stipulated time and this office be accordingly intimated.
3. Office file for record.



[Handwritten Signature]
Principal
Delhi Public School
Leh-Ladakh